

CONSUMER CONFIDENCE REPORT

Halstad

2018 DRINKING WATER REPORT



Making Safe Drinking Water

Your drinking water comes from a groundwater source: two wells ranging from 293 to 297 feet deep, that draw water from the Quaternary Buried Artesian aquifer.

Halstad works hard to provide you with safe and reliable drinking water that meets federal and state water quality requirements. The purpose of this report is to provide you with information on your drinking water and how to protect our precious water resources.

Contact Lucas Spaeth, Superintendent, at 218-456-2128 if you have questions about Halstad's drinking water. You can also ask for information about how you can take part in decisions that may affect water quality.

The U.S. Environmental Protection Agency sets safe drinking water standards. These standards limit the amounts of specific contaminants allowed in drinking water. This ensures that tap water is safe to drink for most people. The U.S. Food and Drug Administration regulates the amount of certain contaminants in bottled water. Bottled water must provide the same public health protection as public tap water.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Halstad Monitoring Results

This report contains our monitoring results from January 1 to December 31, 2018.

We work with the Minnesota Department of Health to test drinking water for more than 100 contaminants. It is not unusual to detect contaminants in small amounts. No water supply is ever completely free of contaminants. Drinking water standards protect Minnesotans from substances that may be harmful to their health.

Learn more by visiting the Minnesota Department of Health's webpage [Basics of Monitoring and Testing of Drinking Water in Minnesota \(https://www.health.state.mn.us/communities/environment/water/factsheet/sampling.html\)](https://www.health.state.mn.us/communities/environment/water/factsheet/sampling.html).

How to Read the Water Quality Data Tables

The tables below show the contaminants we found last year or the most recent time we sampled for that contaminant. They also show the levels of those contaminants and the Environmental Protection Agency's limits. Substances that we tested for but did not find are not included in the tables.

We sample for some contaminants less than once a year because their levels in water are not expected to change from year to year. If we found any of these contaminants the last time we sampled for them, we included them in the tables below with the detection date.

We may have done additional monitoring for contaminants that are not included in the Safe Drinking Water Act. To request a copy of these results, call the Minnesota Department of Health at 651-201-4700 or 1-800-818-9318 between 8:00 a.m. and 4:30 p.m., Monday through Friday.

CONSUMER CONFIDENCE REPORT

Definitions

- **AL (Action Level):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- **EPA:** Environmental Protection Agency
- **MCL (Maximum contaminant level):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **MCLG (Maximum contaminant level goal):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- **Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
- **MRDL (Maximum residual disinfectant level):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **MRDLG (Maximum residual disinfectant level goal):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **NA (Not applicable):** Does not apply.
- **NTU (Nephelometric Turbidity Units):** A measure of the cloudiness of the water (turbidity).
- **pCi/l (picocuries per liter):** A measure of radioactivity.
- **ppb (parts per billion):** One part per billion in water is like one drop in one billion drops of water, or about one drop in a swimming pool. ppb is the same as micrograms per liter (µg/l).
- **ppm (parts per million):** One part per million is like one drop in one million drops of water, or about one cup in a swimming pool. ppm is the same as milligrams per liter (mg/l).
- **PWSID:** Public water system identification.
- **TT (Treatment Technique):** A required process intended to reduce the level of a contaminant in drinking water.
- **Variances and Exemptions:** State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Monitoring Results – Regulated Substances

LEAD AND COPPER – Tested at customer taps.

Contaminant (Date, if sampled in previous year)	EPA's Action Level	EPA's Ideal Goal (MCLG)	90% of Results Were Less Than	Number of Homes with High Levels	Violation	Typical Sources
Copper (06/27/17)	90% of homes less than 1.3 ppm	0 ppm	0.36 ppm	0 out of 10	NO	Corrosion of household plumbing.
Lead (06/27/17)	90% of homes less than 15 ppb	0 ppb	3.8 ppb	0 out of 10	NO	Corrosion of household plumbing.

CONSUMER CONFIDENCE REPORT

INORGANIC & ORGANIC CONTAMINANTS – Tested in drinking water.

Contaminant (Date, if sampled in previous year)	EPA's Limit (MCL)	EPA's Ideal Goal (MCLG)	Highest Average or Highest Single Test Result	Range of Detected Test Results	Violation	Typical Sources
Nitrate	10.4 ppm	10 ppm	1.4 ppm	N/A	NO	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Combined Radium (2015)	5.4 pCi/l	0 pCi/l	1.3 pCi/l	N/A	NO	Erosion of natural deposits.

CONTAMINANTS RELATED TO DISINFECTION – Tested in drinking water.

Substance (Date, if sampled in previous year)	EPA's Limit (MCL or MRDL)	EPA's Ideal Goal (MCLG or MRDLG)	Highest Average or Highest Single Test Result	Range of Detected Test Results	Violation	Typical Sources
Total Trihalomethanes (TTHMs)	80 ppb	N/A	2.2 ppb	N/A	NO	By-product of drinking water disinfection.
Total Haloacetic Acids (HAA) (2017)	60 ppb	N/A	2.2 ppb	N/A	NO	By-product of drinking water disinfection.
Total Chlorine	4.0 ppm	4.0 ppm	0.3 ppm	0.12 - 0.57 ppm	NO	Water additive used to control microbes.

Total HAA refers to HAA5

OTHER SUBSTANCES – Tested in drinking water.

Substance (Date, if sampled in previous year)	EPA's Limit (MCL)	EPA's Ideal Goal (MCLG)	Highest Average or Highest Single Test Result	Range of Detected Test Results	Violation	Typical Sources
Fluoride	4.0 ppm	4.0 ppm	0.65 ppm	0.55 - 0.78 ppm	NO	Erosion of natural deposits; Water additive to promote strong teeth.

CONSUMER CONFIDENCE REPORT

Potential Health Effects and Corrective Actions (If Applicable)

Fluoride: If your drinking water fluoride levels are below the optimal concentration range of 0.7 to 1.2 ppm, please talk with your dentist about how you can protect your teeth and your family's teeth from tooth decay and cavities. For more information, visit: MDH Drinking Water Fluoridation (<http://www.health.state.mn.us/divs/eh/water/com/fluoride/index.html>).

Copper: During the year, we failed to provide lead results to persons served at the sites that were tested as required by the Lead and Copper Rule during the timeframe allowed

Lead: During the year, we failed to provide lead results to persons served at the sites that were tested as required by the Lead and Copper Rule during the timeframe allowed

Monitoring Results – Unregulated Substances

In addition to testing drinking water for contaminants regulated under the Safe Drinking Water Act, we sometimes also monitor for contaminants that are not regulated. Unregulated contaminants do not have legal limits for drinking water.

Detection alone of a regulated or unregulated contaminant should not cause concern. The meaning of a detection should be determined considering current health effects information. We are often still learning about the health effects, so this information can change over time.

The following table shows the unregulated contaminants we detected last year, as well as human-health based guidance values for comparison, where available. The comparison values are based only on potential health impacts and do not consider our ability to measure contaminants at very low concentrations or the cost and technology of prevention and/or treatment. They may be set at levels that are costly, challenging, or impossible for water systems to meet (for example, large-scale treatment technology may not exist for a given contaminant).

A person drinking water with a contaminant at or below the comparison value would be at little or no risk for harmful health effects. If the level of a contaminant is above the comparison value, people of a certain age or with special health conditions - like a fetus, infants, children, elderly, and people with impaired immunity – may need to take extra precautions. Because these contaminants are unregulated, EPA and MDH require no particular action based on detection of an unregulated contaminant. We are notifying you of the unregulated contaminants we have detected as a public education opportunity.

- More information is available on MDH's [A-Z List of Contaminants in Water](https://www.health.state.mn.us/communities/environment/water/contaminants/index.html) (<https://www.health.state.mn.us/communities/environment/water/contaminants/index.html>) and Fourth Unregulated Contaminant Monitoring Rule (UCMR 4) (<https://www.health.state.mn.us/communities/environment/water/com/ucmr4.html>).

UNREGULATED CONTAMINANTS – Tested in drinking water.

Contaminant	Comparison Value	Highest Average Result or Highest Single Test Result	Range of Detected Test Results
Sulfate	500000 ppb	206 ppb	N/A
Sodium*	20 ppm	416 ppm	N/A

*Note that home water softening can increase the level of sodium in your water.

CONSUMER CONFIDENCE REPORT

Some People Are More Vulnerable to Contaminants in Drinking Water

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. The developing fetus and therefore pregnant women may also be more vulnerable to contaminants in drinking water. These people or their caregivers should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

Learn More about Your Drinking Water

Drinking Water Sources

Minnesota's primary drinking water sources are groundwater and surface water. Groundwater is the water found in aquifers beneath the surface of the land. Groundwater supplies 75 percent of Minnesota's drinking water. Surface water is the water in lakes, rivers, and streams above the surface of the land. Surface water supplies 25 percent of Minnesota's drinking water.

Contaminants can get in drinking water sources from the natural environment and from people's daily activities. There are five main types of contaminants in drinking water sources.

- **Microbial contaminants**, such as viruses, bacteria, and parasites. Sources include sewage treatment plants, septic systems, agricultural livestock operations, pets, and wildlife.
- **Inorganic contaminants** include salts and metals from natural sources (e.g. rock and soil), oil and gas production, mining and farming operations, urban stormwater runoff, and wastewater discharges.
- **Pesticides and herbicides** are chemicals used to reduce or kill unwanted plants and pests. Sources include agriculture, urban stormwater runoff, and commercial and residential properties.
- **Organic chemical contaminants** include synthetic and volatile organic compounds. Sources include industrial processes and petroleum production, gas stations, urban stormwater runoff, and septic systems.
- **Radioactive contaminants** such as radium, thorium, and uranium isotopes come from natural sources (e.g. radon gas from soils and rock), mining operations, and oil and gas production.

The Minnesota Department of Health provides information about your drinking water source(s) in a source water assessment, including:

- How Halstad is protecting your drinking water source(s);
- Nearby threats to your drinking water sources;
- How easily water and pollution can move from the surface of the land into drinking water sources, based on natural geology and the way wells are constructed.

Find your source water assessment at [Source Water Assessments](https://www.health.state.mn.us/communities/environment/water/swp/swa) (<https://www.health.state.mn.us/communities/environment/water/swp/swa>) or call 651-201-4700 or 1-800-818-9318 between 8:00 a.m. and 4:30 p.m., Monday through Friday.

Lead in Drinking Water

You may be in contact with lead through paint, water, dust, soil, food, hobbies, or your job. Coming in contact with lead can cause serious health problems for everyone. There is no safe level of lead. Babies, children under six years, and pregnant women are at the highest risk.

CONSUMER CONFIDENCE REPORT

Lead is rarely in a drinking water source, but it can get in your drinking water as it passes through lead service lines and your household plumbing system. Halstad provides high quality drinking water, but it cannot control the plumbing materials used in private buildings.

Read below to learn how you can protect yourself from lead in drinking water.

- 1. Let the water run** for 30-60 seconds before using it for drinking or cooking if the water has not been turned on in over six hours. If you have a lead service line, you may need to let the water run longer. A service line is the underground pipe that brings water from the main water pipe under the street to your home.
 - You can find out if you have a lead service line by contacting your public water system, or you can check by following the steps at: <https://www.mprnews.org/story/2016/06/24/npr-find-lead-pipes-in-your-home>
 - The only way to know if lead has been reduced by letting it run is to check with a test. If letting the water run does not reduce lead, consider other options to reduce your exposure.
- 2. Use cold water** for drinking, making food, and making baby formula. Hot water releases more lead from pipes than cold water.
- 3. Test your water.** In most cases, letting the water run and using cold water for drinking and cooking should keep lead levels low in your drinking water. If you are still concerned about lead, arrange with a laboratory to test your tap water. Testing your water is important if young children or pregnant women drink your tap water.
 - Contact a Minnesota Department of Health accredited laboratory to get a sample container and instructions on how to submit a sample:
[Environmental Laboratory Accreditation Program](https://eldo.web.health.state.mn.us/public/accreditedlabs/labsearch.seam)
(<https://eldo.web.health.state.mn.us/public/accreditedlabs/labsearch.seam>)
The Minnesota Department of Health can help you understand your test results.
- 4. Treat your water** if a test shows your water has high levels of lead after you let the water run.
 - Read about water treatment units:
[Point-of-Use Water Treatment Units for Lead Reduction](https://www.health.state.mn.us/communities/environment/water/factsheet/poulead.html)
(<https://www.health.state.mn.us/communities/environment/water/factsheet/poulead.html>)

Learn more:

- Visit [Lead in Drinking Water](https://www.health.state.mn.us/communities/environment/water/contaminants/lead.html)
(<https://www.health.state.mn.us/communities/environment/water/contaminants/lead.html>)
- Visit [Basic Information about Lead in Drinking Water](http://www.epa.gov/safewater/lead) (<http://www.epa.gov/safewater/lead>)
- Call the EPA Safe Drinking Water Hotline at 1-800-426-4791. To learn about how to reduce your contact with lead from sources other than your drinking water, visit [Lead Poisoning Prevention: Common Sources](https://www.health.state.mn.us/communities/environment/lead/sources.html)
(<https://www.health.state.mn.us/communities/environment/lead/sources.html>).

Help Protect Our Most Precious Resource – Water

You Can Prevent Pollution

Many of our daily activities contribute to the pollution of Minnesota's surface water and groundwater. You can help protect these drinking water sources by taking the following actions:

- Lawn and property:
 - Limit use of herbicides, pesticides, and fertilizers on your property.

CONSUMER CONFIDENCE REPORT

- Keep soil in place with plants, grass, or rocks.
- Cover temporary piles of dirt with a tarp or burlap sack.
- Keep leaves and grass off of streets and sidewalks.
- Maintain any septic systems, private wells, and storage tanks to prevent leaks. Seal any unused wells.
- Out-of-date medications: Never flush unwanted or out-of-date medications down the toilet or sink. Always take them to a waste disposal or prescription medication drop-off site. More information is available at [Managing unwanted medications \(www.pca.state.mn.us/living-green/managing-unwanted-medications\)](http://www.pca.state.mn.us/living-green/managing-unwanted-medications)
- Hazardous materials: Safety store hazardous materials such as paint, batteries, herbicides, pesticides, and pool chemicals. Dispose of them at a proper waste disposal facility or drop-off event. Do not dump down storm drains, sink or onto your land. Learn more at: [Keep hazardous waste out of the garbage \(http://www.pca.state.mn.us/featured/keep-hazardous-waste-out-garbage\)](http://www.pca.state.mn.us/featured/keep-hazardous-waste-out-garbage).
- Pet waste: Pick up after your pet and bring waste to the compost collection site.
- Trash: Seal trash bags and keep litter out of the street.
- Winter ice removal: Chemicals used to break up the ice are called deicers or anti-icers. They can be harmful to the environment, corrosive to driveways and sidewalks and harmful to plants, pets and humans. Always shovel first, and then only apply deicers/anti-icers lightly if needed. Learn more at [10 smart salting tips to protect Minnesota waters \(https://www.pca.state.mn.us/featured/10-smart-salting-tips-protect-minnesota-waters\)](https://www.pca.state.mn.us/featured/10-smart-salting-tips-protect-minnesota-waters).
- Keep an eye out for car and motor fluids: Seal or repair any fluid leaks that could run off onto streets and into storm drains. Take used motor oil or other fluids to a neighborhood drop-off site.
- Be a water advocate: Spread the word; get involved. There are many groups and individuals working to protect water across Minnesota.

Home Water Treatment

Overview

Most Minnesotans, whether they drink from a public water supply or a private well, have drinking water that does not need treatment for health protection. Water treatment units are best for improving the physical qualities of water—the taste, color, or odor.

No single treatment process can remove all substances in water. If you decide to install a home water treatment unit, choose a unit certified and labeled to reduce or remove the substance of concern. If there is more than one substance you want to remove from your water, you may need to combine several treatment processes into one system.

Even well-designed treatments systems can fail. You should continue to test your drinking water after you install a treatment unit. All home water treatment units need regular maintenance to work correctly. Regular maintenance may include changing filters, disinfecting the unit, or cleaning scale buildup. Always install, clean, and maintain a treatment unit according to the manufacturer's recommendations.

Learn more at [Home Water Treatment \(https://www.health.state.mn.us/communities/environment/water/factsheet/hometreatment.html\)](https://www.health.state.mn.us/communities/environment/water/factsheet/hometreatment.html).

Beware of Water Treatment Scams

False claims, deceptive sales pitches, or scare tactics have been used by some water treatment companies. Every person has a right to decide what is best for themselves and their family, and you may choose to install additional water treatment to further lower the levels of contaminants of emerging concern, chlorine, and other chemicals in your water. However, you should be cautious about purchasing a water treatment system. If you are considering the purchase of a home water treatment system, please read the Minnesota Department of Health's recommendations online at [Warning: Beware of Water Treatment Scams \(https://www.health.state.mn.us/communities/environment/water/factsheet/beware.html\)](https://www.health.state.mn.us/communities/environment/water/factsheet/beware.html).

CONSUMER CONFIDENCE REPORT

The Pros and Cons of Home Water Softening

When considering whether to use a water softener, contact your public water system to find out if you have hard water. Many systems treat for hardness, making water softeners unnecessary.

Water softeners are a water treatment device. They remove water hardness (dissolved calcium and magnesium). Water softeners must be installed and maintained properly to be safe and effective. Learn more at [Home Water Softening \(https://www.health.state.mn.us/communities/environment/water/factsheet/softening.html\)](https://www.health.state.mn.us/communities/environment/water/factsheet/softening.html).

The benefits of soft water include:

- Increased efficiency for soaps and detergents.
- Reduction in mineral staining on fixtures and in pipes.
- A potential increase in the lifespan of water heaters.

The drawbacks of soft water include:

- Operation and maintenance costs.
- More sodium. People on low-sodium diets should consult a doctor if they plan to regularly consume softened water.
- The production of salt brine as a byproduct. This can have negative effects at wastewater treatment plants and on ecosystems. Reduce the amount of salt brine used or install a salt-free system.